


UNIVERSITY OF TOLEDO PVIC SOLAR ARRAY MODIFICATIONS

June 27, 2013

Prepared by Ted Davis and Randy Ellingson

Current Configuration

Array #2 wired for the electrolyzer as follows: All 108 panels are wired in parallel resulting in an mpp at STC of $V_{mpp} = 62 \text{ V}$ and $I_{mpp} = 100.5 \text{ A}$. There are six zones, each of which can be turned off or on presumably affecting the total current delivered.



Array #1 wired for connection to the SunnyBoy inverter (grid-tied) such that sets of six modules are wired together in series into a “string”, and then 18 “string” of 6 modules are wired in parallel resulting in an mpp at STC of $V_{mpp} = 372 \text{ V}$ and $I_{mpp} = 16.7 \text{ A}$.

Assumptions:

- Electricity Cost: \$0.05/kWh
- No upgrade to existing electrical service
- Electrician labor: \$100/hr
- Time to rewire a module: one electrician, 5 minutes
- Replace a First Solar module (Scenarios B and C):
2 electricians working for 10 minutes
- Install power inverter: 2 men, 2 hours
- Solar module cost = \$1.00/watt
- Resale of used First Solar modules = \$0.30/Watt

Scenario A

Tie Array #2 to Grid (add inverter)

Scenario A: Current Solar Modules

- Manufacturer: First Solar
- Model #: FS-257 CdTe
- Electrical Specs @ STC
 - Power: 58 Watts
 - Voltage: 61.5 Volts
 - Current: .94 Amps
 - Efficiency: 8%
- Mechanical Spec.
 - Width: 600 mm
 - Length: 1200 mm
 - Area: 0.72 m
 - Weight: 25.1 lbs.

Scenario A: Configuration

Solar Array - Schema 1				Building R1							
108 Panels (FS-257)				Array # 2 (Tied to Grid)							
HD Safety Switch 1				6,210 W DC (Peak Power @ STC)							
6 Panels				372 VDC Nominal Peak Voltage, 534 VDC (Open Circuit Voltage)							
6 Panels				16.74 Amps (Peak Power Current), 20.34 Amps (Short Circuit Current)							
String 1				String 3 - (6 Panels)		String 7 - (6 Panels)		String 11 - (6 Panels)		String 15 - (6 Panels)	
6 Panels				String 4 - (6 Panels)		String 8 - (6 Panels)		String 12 - (6 Panels)		String 16 - (6 Panels)	
String 2				String 5 - (6 Panels)		String 9 - (6 Panels)		String 13 - (6 Panels)		String 17 - (6 Panels)	
6 Panels				String 6 - (6 Panels)		String 10 - (6 Panels)		String 14 - (6 Panels)		String 18 - (6 Panels)	
Sensor				String 6 - (6 Panels)		String 10 - (6 Panels)		String 14 - (6 Panels)		String 18 - (6 Panels)	
Each String has 6 Panels in Series											
108 Panels (FS-257)				Array # 1 (Tied to Grid)				6,210 W DC (Peak Power @ STC)			
HD Safety Switch 1				372 VDC Nominal Peak Voltage, 534 VDC (Open Circuit Voltage)				16.74 Amps (Peak Power Current), 20.34 Amps (Short Circuit Current)			
6 Panels				String 3 - (6 Panels)		String 7 - (6 Panels)		String 11 - (6 Panels)		String 15 - (6 Panels)	
6 Panels				String 4 - (6 Panels)		String 8 - (6 Panels)		String 12 - (6 Panels)		String 16 - (6 Panels)	
String 2				String 5 - (6 Panels)		String 9 - (6 Panels)		String 13 - (6 Panels)		String 17 - (6 Panels)	
6 Panels				String 6 - (6 Panels)		String 10 - (6 Panels)		String 14 - (6 Panels)		String 18 - (6 Panels)	
Each String has 6 Panels in Series											
				Dorr St							

Scenario A: DC Output Expected from Array #2

- 6 Panels/String
- 18 Strings
- 108 Panels
- 6,210 W DC (peak power @ Standard Test Conditions (STC))
- 372 VDC nominal peak voltage
- 534 VDC open circuit voltage
- 16.74 Amps at maximum power point (mpp)
- 20.34 short circuit current

Scenario A: AC Output Expected from Array #2 = 7,533 kW-hr/yr



AC Energy
&
Cost Savings



(Type comments here to appear on printout; maximum 1 row of 90 characters.)

Station Identification		Results			
Cell ID:	0249368	Month	Solar Radiation (kWh/m ² /day)	AC Energy (kWh)	Energy Value (\$)
State:	Ohio	1	3.06	471	23.55
Latitude:	41.8 ° N	2	3.85	538	26.90
Longitude:	83.8 ° W	3	4.63	689	34.45
PV System Specifications		4	5.49	765	38.25
DC Rating:	6.21 kW	5	5.66	778	38.90
DC to AC Derate Factor:	0.770	6	5.88	756	37.80
AC Rating:	4.78 kW	7	5.74	751	37.55
Array Type:	Fixed Tilt	8	5.64	746	37.30
Array Tilt:	41.8 °	9	5.43	713	35.65
Array Azimuth:	180.0 °	10	4.17	585	29.25
Energy Specifications		11	2.73	383	19.15
Cost of Electricity:	5.0 ¢/kWh	12	2.40	358	17.90
		Year	4.56	7533	376.65

Scenario A: Cost

- Inverter: SunnyBoy SB6000US 1 Phase - **\$2,735**
- Rewire 108 modules from parallel to 18 groups of 6 modules per string - **\$900**
- Install inverter, attach to electrical panel, and connect to grid - **\$400**
- -----
- Total **\$4,035**

Scenario B: Upgrade Array #2 and Tie to Grid (new inverter)

Scenario #2

Upgrade First Solar Panels

- Manufacturer: First Solar
- Model: FS-390 CdTe

- Electrical Specs @ STC
 - Power: 90 Watts
 - Voltage: 49.2 Volts
 - Current: 1.83 Amps
 - Efficiency: 13%

- Mechanical Spec.
 - Width: 600 mm
 - Length: 1200 mm
 - Area: 0.72 meters
 - Weight: 12 lbs.

Scenario #2- Configuration

Solar Array - Schema 2				Building R1			
108 Panels (FS-390)				Array # 2 (Tied to Grid)			
				9,724 W DC (Peak Power @ STC)			
				443 VDC Nominal Peak Voltage, 549 VDC (Open Circuit Voltage)			
				22 Amps (Peak Power Current), 24 Amps (Short Circuit Current)			
HD Safety Switch 1							
String 1 - (9 Panels)				String 5 - (9 Panels)			
String 2 - (9 Panels)				String 6 - (9 Panels)			
String 3 - (9 Panels)				String 7 - (9 Panels)			
String 4 - (9 Panels)				String 8 - (9 Panels)			
String 9 - (9 Panels)				String 10 - (9 Panels)			
String 11 - (9 Panels)				String 12 - (9 Panels)			
Each String has 9 Panels in Series							
108 Panels (FS-257)				Array # 1 (Tied to Grid)			
				6,210 W DC (Peak Power @ STC)			
				372 VDC Nominal Peak Voltage, 534 VDC (Open Circuit Voltage)			
				16.74 Amps (Peak Power Current), 20.34 Amps (Short Circuit Current)			
HD Safety Switch 1							
String 1 - (6 Panels)				String 7 - (6 Panels)			
String 2 - (6 Panels)				String 8 - (6 Panels)			
String 3 - (6 Panels)				String 9 - (6 Panels)			
String 4 - (6 Panels)				String 10 - (6 Panels)			
String 5 - (6 Panels)				String 11 - (6 Panels)			
String 6 - (6 Panels)				String 12 - (6 Panels)			
String 13 - (6 Panels)				String 14 - (6 Panels)			
String 15 - (6 Panels)				String 16 - (6 Panels)			
String 17 - (6 Panels)				String 18 - (6 Panels)			
Each String has 6 Panels in Series							
Dorr St							

Scenario B: DC Output

- 9 Panels/String
- 12 Strings
- 108 Panels
- 9,700 W DC (Peak Power @ STC)
- 443 VDC Nominal Peak Voltage
- 549 VDC (Open Circuit Voltage)
- 21.96 Amps (Peak Power Current)
- 24.48 Amps (Short Circuit Current)

Scenario B: AC Output = 11,791 kW-hr / year



AC Energy
&
Cost Savings



(Type comments here to appear on printout; maximum 1 row of 90 characters.)

Station Identification		Results			
Cell ID:	0249368	Month	Solar Radiation (kWh/m ² /day)	AC Energy (kWh)	Energy Value (\$)
State:	Ohio	1	3.06	738	36.90
Latitude:	41.8 ° N	2	3.85	842	42.10
Longitude:	83.8 ° W	3	4.63	1078	53.90
PV System Specifications		4	5.49	1198	59.90
DC Rating:	9.72 kW	5	5.66	1218	60.90
DC to AC Derate Factor:	0.770	6	5.88	1183	59.15
AC Rating:	7.48 kW	7	5.74	1176	58.80
Array Type:	Fixed Tilt	8	5.64	1168	58.40
Array Tilt:	41.8 °	9	5.43	1115	55.75
Array Azimuth:	180.0 °	10	4.17	915	45.75
Energy Specifications		11	2.73	599	29.95
Cost of Electricity:	5.0 ¢/kWh	12	2.40	560	28.00
		Year	4.56	11791	589.55

Scenario B: Cost

- Buy 108 - FS-390 First Solar Panels - **\$9,724**
- Remove old Panels and Install new ones – **\$3,600**
- Rewire Solar panels with 9 panels in series per string - **\$900**
- Buy inverter 10000TL-US - **\$5,600**
- Install inverter, attach to electrical panel, and connect to grid - **\$400**
- Sell Used Panels – **(\$1,880)**
- -----
- Total - **\$ 18,344**

Scenario C

Tie Array #2 to Grid; Upgrade Modules for Both Arrays; Requires new inverter(s)


Scenario C: Upgrade Both Arrays to First Solar FS-390 Modules

- Manufacturer: First Solar
- Model: FS-390 CdTe

- Electrical Specs @ STC
 - Power: 90 Watts
 - Voltage: 49.2 Volts
 - Current: 1.83 Amps
 - Efficiency: 13%

- Mechanical Spec.
 - Width: 600 mm
 - Length: 1200 mm
 - Area: 0.72 meters
 - Weight: 26.4 lbs.

Scenario C: Configuration



Scenario C: DC Output / Array

- 9 Panels/String
- 12 Strings
- 108 Panels
- 9,700 W DC (Peak Power @ STC)
- 443 VDC Nominal Peak Voltage
- 549 VDC (Open Circuit Voltage)
- 21.96 Amps (Peak Power Current)
- 24.48 Amps (Short Circuit Current)

Scenario C: Total AC Output = 23,582 kW-hr/yr

Configuration #3 - Attach Array #2 to the Grid. Upgrade both Arrays with FS-390

Station Identification		Results			
City:	Toledo	Month	Solar Radiation (kWh/m ² /day)	AC Energy (kWh)	Energy Value (\$)
State:	Ohio	1	2.90	1401	0.70
Latitude:	41.60° N	2	3.82	1676	0.84
Longitude:	83.80° W	3	4.24	1974	0.99
Elevation:	211 m	4	5.30	2321	1.16
PV System Specifications		5	5.71	2454	1.23
DC Rating:	19.4 kW	6	5.60	2269	1.13
DC to AC Derate Factor:	0.770	7	5.80	2379	1.19
AC Rating:	14.9 kW	8	5.70	2373	1.19
Array Type:	Fixed Tilt	9	5.13	2104	1.05
Array Tilt:	41.6°	10	3.87	1708	0.85
Array Azimuth:	180.0°	11	2.57	1132	0.57
Energy Specifications		12	2.17	1019	0.51
Cost of Electricity:	0.1 ¢/kWh	Year	4.40	22810	11.41

Output Hourly Performance Data Output Results as Text

[About the Hourly Performance Data](#) [Saving Text from a Browser](#)

Scenario C: Cost*

- Buy 216 - FS-390 First Solar Panels - \$19,448
- Remove old Panels and Install new ones – \$7,200
- Rewire Solar panels with 12 panels in series per string - \$1,800
- Buy 2 inverters 10000TL-US - \$11,200
- Install 2 inverter, attach to electrical panel, and connect to grid - \$800
- Sell Used Panels – (\$3,760)
- -----
- Total - \$ 36,688

LEC Assumptions

- \$0.05 / kWh
- 1% increase in Electric Price/Year
- 0.5% yearly decrease in power output due to module aging
- 3.5% Discount Rate

Comparison

	Scenario A	Scenario B	Scenario C
	Attach to Grid	Attach to Grid, Upgrade to new Panels FS-390	Attach to Grid, Upgrade both Arrays to new Panels FS-390
Cost	\$4,035	\$18,344	\$36,688
Annual kWh	7,355	11,791	23,582
LEC Break Even	10 Years	Never	Never
LEC @ 10 Years	\$0.053/kWh	\$0.133/kWh	\$0.191/kWh
LEC @ 15 Years	\$0.040/kWh	\$0.099/kWh	\$0.140/kWh
LEC @ 20 Years	\$0.034/kWh	\$0.082/kWh	\$0.115/kWh
LEC @ 25 Years	\$0.031/kWh	\$0.072/kWh	\$0.101/kWh

Energy Cost Increase

	Grid Energy Cost	Scenario A	Scenario B	Scenario C
	Cost @ 25 Years	Attach to Grid	Attach to Grid, Upgrade to new Panels FS-390	Attach to Grid, Upgrade both Arrays Panels FS-390
Starting Cost	\$0.05/kWh	Break Even	Break Even	Break Even
1% Increase/Yr	\$0.063/kWh	10 Years	> 25 Years	> 25 Years
3% Increase/Yr	\$0.102/kWh	9 Years	19 Years	25 Years
5% Increase/Yr	\$0.154/kWh	8 Years	15 Years	19 Years